

## **Slip Check to AS 4586:2013**

### **Ultramat - colour me loop pile - 24 oz insert**

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

15 August 2016

## Test Report No. M0210a

### Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Birrus Matting Systems  
Client Address: 12 Overseas Drive  
Noble Park North VIC 3174  
Product Manufacturer: Birrus Matting Systems  
Product Description: Ultramat - colour me loop pile - 24 oz insert

Test conducted according to: AS 4586:2013 Appendix A  
Location: Slip Check Pty Ltd Test Facilities, Melbourne VIC 3000  
Conducted by: Nasser Cura

Date: 12 August 2016      Temperature: 20°C  
Sample: Unfixed      Cleaning: None  
Rubber slider used: Slider 96      Conditioned: Grade P 400 paper dry followed by wet lapping film  
Slope of specimen: Tested on a flat level surface  
Direction of Test: Approximately 90° to profile

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	57	55	51	54	54

<b>Reported SRV of Sample:</b>	<b>54</b>
<b>Class:</b>	<b>P4</b>



  
Ryan Voorderhake  
Technician